

Bellaterra : 03rd March 2020  
Dossier number : **19/21100-3618**  
Petitioner's reference : **TOPCRET**  
Gran Via de les Corts Catalanes 828  
08016 Barcelona

## TEST REPORT

### **RECEIVED MATERIAL**

On december 12th, 2019, Applus Laboratories received several applied substrates of mortar with the following reference:

### **METALLIC EDITION**

### **REQUESTED TESTS:**

- 1- Determination of liquid water permeability, UNE-EN 1062-3:2008
- 2- Determination of resistance to strong chemical attacks, UNE- EN 13529

**TESTS DATE:** from 11/12/2019 to 25/02/2020

**RESULTS:** See annexes pages

Responsible for Construction Mat.  
LGAI Technological Center, S.A.

Technician Responsible  
LGAI Technological Center, S.A.

The results specified in this document correspond exclusively to the material received in Applus Laboratories and tested according to the indications that they present.

The reproduction of this document is only authorised if it is made in its totality. Electronically signed reports in digital format are considered original documents, as well as its electronic copies. Their printing has no legal validity.

Report no. 19/21100-3618	Page 2
<b>TOPCRET</b>	<b>METALLIC EDITION</b>

**RESULTS:**

**1- Determination of liquid water permeability, UNE-EN 1062-3:2008**

Specimen no.	W (Kg/m <sup>2</sup> h <sup>0,5</sup> )
1	0,001
2	0,001
3	0,001
<b>Mean</b>	<b>0,001</b>

**2- Determination of resistance to strong chemical attacks, UNE- EN 13529**

After exposing the product to the selected reagents by the petitioner for 3 days, the following is observed:

Olive oil	No changes
Red wine	No changes
Alcohol	A slight loss of color is observed
Bleach	Color change is observed
Hair Dye	A slight color change is observed
Vinager	A slight color change is observed
Viakal	A slight color change is observed
Lemon juice	No changes

**Service Quality Assurance**

Applus+, guarantees that this work has been made in accordance with our Quality and Sustainability System, fulfilling the contractual conditions and legal norms.

Within our improvement program we would be grateful if you would send us any commentary that you consider opportune, to the person in charge who signs this document, or to the Quality Manager of Applus+, in the following e-mail address: [satisfaccion.cliente@applus.com](mailto:satisfaccion.cliente@applus.com)